

EXISTING EXTERIOR STAIRS
EXISTING ROLLING OVERHEAD DOOR

NEW WIRE MESH PART.
BATTERIES BELOW
NEW FIRE ALARM CONTROL PANEL AND TRANSPONDER

EXISTING ROLLING OVERHEAD DOOR

NEW WIRE MESH PARTITION
EXISTING COLUMN

EXISTING ROLLING OVERHEAD DOOR
EXISTING COLUMN

NEW WIRE MESH PARTITION

EXPOSED CONDUIT PERMITTED

NEW FIRE ALARM CONTROL PANEL AND TRANSPONDER

BATTERIES

NEW WIRE MESH PARTITION

EXISTING ROLLING OVERHEAD DOOR

EXIST. ELECTRICAL BOXES AND CONDUITS TO REMAIN (RELOCATE AS REQUIRED)
NEW FIRE ALARM CONTROL PANEL AND TRANSPONDER
BATTERIES

NEW WIRE MESH PARTITION

WIRE TO NEAREST EMERGENCY LIGHTING CIRCUIT. (GENERATOR AND POWER) 2#12 & 1#12 G IN 3/4" C
INSTALL IN EXISTING CEILING GRID SEE REFLECTED CEILING PLAN.
MOUNT IN SURFACE BOX
NEW FIRE ALARM PANEL & TRANSPONDER
2#12 & 1#12 G IN 3/4" C; WIRE TO NEW 20/1 C/B IN NEAREST EMERG. PANEL (120/208 V)
BATTERIES
SEE DETAIL MAIN FIRE ALARM PANEL SHEET A-22
WIRE TO NEAREST RECEPT CIRCUIT

FOR FIXTURE SCHEDULE SEE A-12

EXIST. SUSP. CEIL.

TOP CAP
WIRE MESH


HORIZ. SUPPORT

BASE

CONTRACTOR SHALL CHECK AND FIELD VERIFY ALL DIMENSIONS AND REPORT DISCREPANCIES TO THE ARCHITECT BEFORE ANY WORK IS COMMENCED.
ALL DRAWINGS ARE THE PROPERTY OF THE ARCHITECT.

THIS DESIGN AND THESE DOCUMENTS MAY NOT BE REPRODUCED, REUSED, ALTERED OR ADDED TO WITHOUT THE WRITTEN PERMISSION OF THE ARCHITECT.

STATE UNIVERSITY
CONSTRUCTION FUND
SUCF PROJECT NUMBER 12130
REPLACE FIRE ALARM SYSTEM / INSTALL SPRINKLER
CRANE MUSIC COMPLEX
STATE UNIVERSITY COLLEGE AT POTSDAM



HAZEL CONSULTANTS IN ENGINEERING
P.O. BOX 228
CLIFTON PARK, NY 12065
TEL: (518) 877-8586
FAX: (518) 877-8599

OCM PROJECT NO. 10233

O'CONNOR & MARSH
ARCHITECTS

FACILITY DESIGN - PLANNING

517 OVER THE LIBRARY AVENUE
WESTERN AVENUE
ALBANY, NEW YORK 12203
518 459 0611

DRAWING TITLE
SNELL HALL -
PARTIAL PLANS
INTERIOR ELEVATIONS
PARTIAL SECTIONS

DATE
12-9-97

DRAWING NO.
A13

SUCF PROJECT NO.
12130

SCHUETTE HALL (BLDG. NO. 9A)

D116