





D116




1 CONTROL ROOM PLANS - LEVEL 4
SCALE: 1/16" = 1'-0"




3 PARTIAL PLAN - LEVEL 4
SCALE: 1/16" = 1'-0"



4 PARTIAL PLAN - LEVEL 4
SCALE: 1/16" = 1'-0"




2 LIGHTING GALLERY - LEVEL 5
SCALE: 1/16" = 1'-0"



KEY NOTES:



- 1 DROP DOWN TO TEST STATION.
- 2 WIRE BEAM DETECTOR TO ADDRESSABLE MONITOR MODULE. SEE DETAILS. SHEET A-23 MOUNT
- 3 POWER SUPERVISORY RELAY FOR 24VDC TO BEAM SMOKE DETECTOR PROJECTORS. SEE DETAIL FOR WIRING TO MONITOR MODULE AND POWER SUPPLY.
- 4 WIRE TO (FUTURE) SMOKE HATCH AS NOTED. SEE DETAIL. FOR EXISTING HATCHES, REMOVE EXISTING CONTROL, MAINTAIN POWER SUPPLY.
- 5 WIRE TO DISABLE SOUND SYSTEM. SEE DETAIL.
- 6 CAREFULLY COORDINATE EXACT PLACEMENT OF BEAM DETECTORS WITH ARTICULATION OF EXISTING CEILING. MOUNT W/IN 3'-0" OF CEIL. HIGH POINTS. DO NOT RUN CIRCUITING THRU CEIL.

KEY PLAN: CRANE MUSIC COMPLEX



CONTRACTOR SHALL CHECK AND FIELD VERIFY ALL DIMENSIONS AND REPORT DISCREPANCIES TO THE ARCHITECT BEFORE ANY WORK IS COMMENCED.
ALL DRAWINGS ARE THE PROPERTY OF THE ARCHITECT.
THIS DESIGN AND THESE DOCUMENTS MAY NOT BE REPRODUCED, REUSED, ALTERED OR ADDED TO WITHOUT THE WRITTEN PERMISSION OF THE ARCHITECT.

STATE UNIVERSITY
CONSTRUCTION FUND
SUCF PROJECT NUMBER 12130
REPLACE FIRE ALARM SYSTEM / INSTALL SPRINKLER
CRANE MUSIC COMPLEX
STATE UNIVERSITY COLLEGE AT POTSDAM



HAZF CONSULTANTS IN ENGINEERING
P.O. BOX 228
CLIFTON PARK, NY. 12065
TEL: (518) 877-8586
FAX: (518) 877-8599

OCM PROJECT NO. 10233

O'CONNOR & MARSH
ARCHITECTS

FACILITY DESIGN - PLANNING

517 OVER THE LIBRARY
WESTERN AVENUE
ALBANY, NEW YORK 12203
518 459 0611

DRAWING TITLE
HOSMER CONCERT HALL -
LEVEL 4, &
LEVEL 5

DATE
12-9-97

DRAWING NO.
A9

SUCF PROJECT NO.
12130

HOSMER CONCERT HALL (BLDG. NO. 16)