



AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report


Ambient Environmental, Inc.
Attn: Joella Viscusi
12 Colvin Avenue

Albany, NY 12206

Date Received 01/08/14 **AmeriSci Job #** 214011483
Date Examined 01/08/14 **P.O. #**
ELAP # 11480 **Page** 1 of 1
RE: 140107AA; SUNY Potsdam; 44 Pierreponte Ave., Potsdam,
NY ; Timmerman ; Room 132

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
01 0101 Location: Roof Drain Insulation / Room 132, Center	214011483-01	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/08/14
Analyst Description: Grey/White, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 5 %, Fibrous glass 45 %, Non-fibrous 50 %			
02 0101 Location: Roof Drain Insulation / Room 132, Center	214011483-02	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/08/14
Analyst Description: Grey/White, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 10 %, Fibrous glass 45 %, Non-fibrous 45 %			
03 0101 Location: Roof Drain Insulation / Room 132, Center	214011483-03	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/08/14
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 55 %, Non-fibrous 45 %			

Reporting Notes:

Analyzed by: Ella Babayeva 
*NAD/NSD =no asbestos detected, NA =not analyzed, N/A/PS =not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab Code 200546-0), ELAP PLM Method 198.1 for NY friable samples, which includes the identification and quantitation of vermiculite or 198.6 for NOB samples or EPA 400 pt ct by EPA 600/M4-82-020 (NY ELAP Lab ID11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 59,146,38970,8/1/94) National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab.This PLM report relates ONLY to the items tested. AIHA Lab # 102843, RI Cert#AAL-094, CT Cert#PH-0186, Mass Cert#AA000054.

Reviewed By: _____ **END OF REPORT** _____

