



Response Labs, LLC.
 12 Colvin Avenue, Albany NY 12206
 Phone (518) 482-5630 Fax (518) 482-5624
 NYS DOH ELAP # 11917

PLM Bulk Asbestos Report

Client: SUNY Potsdam
 44 Pierrepont Avenue
 Potsdam NY 13676

Client Project Number: 27-010912

Project Name: Timerman Hall
 44 Pierrepont Ave
Sampling Area: Room B006

Laboratory Job Number: 903-452
Sampled By: Client
Collection Date: 1/9/2012
Date Received: 1/11/2012

Lab Sample #	Customer Sample #	Homogeneity	Color	% Non-Fibrous Matrix Material	Gravimetric Test			Total % of Asbestos
					% of Organics	% of Acid Soluble Inorganics	% of Residue	
6573	-TIM-B006PI	Homogeneous	Grey	55%				NAD
Sampled Material: Pipe Elbow					Non-Asbestos Fibers		Asbestos Types:	
Sample Location: x=16.5, y=65.6, z=1.8					45%	Fiber Glass	No Asbestos Detected	
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1					Analyzed Date: 1/11/2012			
Microscope: Olympus BH-2-214 Turn Around Time: 24 Hour								
6574	-TIM-B006PI	Homogeneous	Grey	72%				3.0%
Sampled Material: Pipe Elbow					Non-Asbestos Fibers		Asbestos Types:	
Sample Location: x=16.5, y=65.6, z=1.8					25%	Fiber Glass	3.0%	Chrysotile
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1					Analyzed Date: 1/11/2012			
Microscope: Olympus BH-2-214 Turn Around Time: 24 Hour								
6575	-TIM-B006PI							NA/PS
Sampled Material: Pipe Elbow					Non-Asbestos Fibers		Asbestos Types:	
Sample Location: x=16.5, y=65.6, z=1.8					Not Analyzed Positive Stop			
Analyzed By: Method: Positive Stop								
Microscope: Turn Around Time: Positive Stop (198.1) Analyzed Date:								


Definitions of Abbreviations: NOB: Non-Organically Bound, Trace: Asbestos Detected at 1% or Less, TEM: Transmission Electron Microscope, Inc.: Inconclusive, NAD: No Asbestos Detected, NA/PS: Not Analyzed Positive Stop, NA: Not Analyzed

Disclaimer: PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. No Asbestos Detected or Trace results by PLM 198.6 are considered inconclusive, TEM is currently the only method that can be used to determine if materials can be considered as non asbestos containing in NY State. This report cannot be reproduced except in full without the approval of Response Labs, LLC. This PLM report relates ONLY to the items tested. Liability is limited to the cost of analysis. ELAP PLM Method 198.1 for friable samples or 198.6 for NOB Samples.

Comments:

Laboratory Director,

Justin Adams



RESPONSE LABS, LLC
 12 Colvin Avenue
 Albany, NY 12206
 PH: 518-482-5630
 FX: 518-482-5624

PURCHASE ORDER #
 301003

BULK SAMPLE DATA AND CHAIN OF CUSTODY FORM

PROJECT INFORMATION

1. Client: SUNNY Potsdam	2. Project Name: Timerman Hall Pipe Elbow	2a. Project Address: 44 Pierrepont Avenue	2b. Client Contact: 315-267-2142
3. Project Number: 27-010912	3a. Task Number:	4. Inspector: Kevin P. Hennessey	5. Collection Date: January 9, 2012
6. Sample TAT: <input checked="" type="checkbox"/> 24 HR <input type="checkbox"/> 48 HR <input type="checkbox"/> 72 HR <input type="checkbox"/> 5 Day <input type="checkbox"/> Other	7. Building Name: Timerman Hall	8. Sampling Areas: Room B006	9. Comments: (Field) <input checked="" type="checkbox"/> Analyze to First Positive By Homogeneous Material <input checked="" type="checkbox"/> For Negative NOB PLM's, continue to TEM

10. Laboratory Sample Number	11. Homogeneous Area Number	12. Bulk Sample ID Number	13. Sampled Material	14. Type of Material			15. Sample Location	16. Friability (N/F)	17. Condition (G, D, SD)	18. Quantity (LF, SF, EA)	19. Asbestos Content (Type & %)
				Surf	TSI	MISC					
6573	1-TIM	1-TIM-B006PE	Pipe Elbow	X			X 16.5 Y = 65.6 Z = 1.8	F	G		
6574	1-TIM	2-TIM-B006PE	Pipe Elbow	X			X = 16.5 Y = 65.6 Z = 1.8	F	G		
6575	1-TIM	3-TIM-B006PE	Pipe Elbow	X			X = 16.5 Y = 65.6 Z = 1.8	F	G		

CHAIN OF CUSTODY

20. Relinquished By: <i>Kevin P. Hennessey</i>	21. Date: 1/9/12	22. Time: 14:10	23. Received By: <i>[Signature]</i>	24. Date: 1/11/12	25. Time: 1414

LAB INFORMATION

26. Lab Name: Response Labs	27. Date: 1/9/12	28. Time:
a. Analyzed By: 		
b. QC by: 		
c. Lab Batch #: 403-452		

29. Project Manager: 	30. Results To: Phone #'s: Fax: 	31. Drawings: <input type="checkbox"/> Sample Locations <input type="checkbox"/> Material Locations	32. Comments:
-------------------------------	---	---	------------------------