



ATLANTIC TESTING LABORATORIES

Canton
6431 U.S. Highway 11
P.O. Box 29
Canton, NY 13617
315-386-4578 (T)
315-386-1012 (F)

January 19, 2009

State University of New York at Potsdam
44 Pierrepont Avenue
Potsdam, New York 13676

Attn: Andrew Martin

Re: Directed Bulk Sampling and Analysis
Center Corridor
Timerman Hall
State University of New York at Potsdam
Potsdam, New York
ATL Report No. CT5657A-01-01-09

Ladies/Gentlemen:

Atlantic Testing Laboratories, Limited (ATL) performed directed bulk sampling of ceiling plaster from within the Timerman Hall situated on the State University of New York (SUNY) at Potsdam campus located in Potsdam, St. Lawrence County, New York, on November 21, 2008. This project was completed in accordance with the scope of work outlined in our contract (ATL No. CT5998-88-06-07), dated June 13, 2007 and authorized by Mr. Larry Leashomb, representing SUNY Potsdam.

Summary of Sampling Activities

The suspect asbestos-containing material (ACM) identified during the visual examination included 1 homogenous building material, from which a total of 2 bulk samples were collected and subsequently submitted to AmeriSci New York, a New York State Department of Health (NYSDOH) approved laboratory (ELAP No. 11480) for analysis by polarized light microscopy (PLM). A copy of the laboratory report and associated sample custody documentation is enclosed. The gray ceiling plaster was determined to be non-ACM.

Sampling Program Limitations

This report has been prepared for SUNY Potsdam, in accordance with the terms and conditions of our contract dated June 13, 2007 (ATL No. CT5998-88-06-07), and should not be used as asbestos abatement specifications or design documents. The sampling data, laboratory reports, and findings/conclusions/recommendations presented in this report are based on the field observations made by representatives of ATL at the time of the sampling event. Samples were collected as directed by Mr. Steven Bracy, representing State University of New York at Potsdam.

Concealed regulated ACM may exist within the center corridor of Timerman Hall that may be encountered during renovation activities. If any suspect ACM is encountered during renovation activities, the activities disturbing the suspect ACM must stop and the material should be sampled and laboratory analyzed in accordance with applicable regulations.

Albany ♦ Binghamton ♦ Elmira ♦ Plattsburgh ♦ Poughkeepsie ♦ Rochester ♦ Syracuse ♦ Utica ♦ Watertown

Summary of Findings


The following summary of findings is prepared from ATL's understanding that material-specific sampling and analysis was requested within the specified area of the referenced building.

1. The **Gray Ceiling Plaster** material sampled was determined to be **non-ACM**.

Please contact our office should you have any questions, or if we may be of further assistance.

Sincerely,

ATLANTIC TESTING LABORATORIES, Limited



Torey J. Russell
Environmental Scientist

TJR/JDG/rfb

Enclosures

cc: Mr. Steven Bracy, SUNY Potsdam

**NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER
RICHARD F. DAINES, M.D.**



Expires 12:01 AM April 01, 2009
Issued April 01, 2008

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

**MR. PAUL MUCHA
AMERICA SCIENCE TEAM NEW YORK INC
117 EAST 30TH ST
NEW YORK, NY 10016**

NY Lab Id No: 11480
EPA Lab Code: NY01378

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*


Miscellaneous

- | | |
|--------------------------------------|---|
| Asbestos in Friable Material | EPA 600/M4/82/020
Item 188.1 of Manual |
| Asbestos in Non-Friable Material-PLM | Item 198.6 of Manual (NOB by PLM) |
| Asbestos in Non-Friable Material-TEM | ITEM 198.4 OF MANUAL |

Serial No.: 36240

Property of the New York State Department of Health. Valid only at the address shown. Must be conspicuously posted. Valid certificates have a raised seal. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify laboratory's accreditation status.

United States Department of Commerce
National Institute of Standards and Technology



Certificate of Accreditation to ISO/IEC 17025:2005

NVLAP LAB CODE: 200546-0

AmeriSci New York
New York, NY

is accredited by the National Voluntary Laboratory Accreditation Program for specific services,
listed on the Scope of Accreditation, for:

BULK ASBESTOS FIBER ANALYSIS

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005.
This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality
management system (refer to joint ISO-ILAC-IAF Communiqué dated 18 June 2005).



2008-07-01 through 2009-06-30

Effective dates

Jolly A. Bucci
For the National Institute of Standards and Technology



**National Voluntary
Laboratory Accreditation Program**



SCOPE OF ACCREDITATION TO ISO/IEC 17025:2005

AmeriSci New York
DBA: AmeriSci New York
 117 E. 30th Street
 New York, NY 10016
 Mr. Paul Mucha
 Phone: 212-679-8600 Fax: 212-679-2711
 E-Mail: pmucha@amerisci.com
 URL: <http://www.amerisci.com>

BULK ASBESTOS FIBER ANALYSIS (PLM)

NVLAP LAB CODE 200546-0

<i>NVLAP Code</i>	<i>Designation / Description</i>
18/A01	EPA-600/M4-82-020: Interim Method for the Determination of Asbestos in Bulk Insulation Samples

2008-07-01 through 2009-06-30

Effective dates

Sally A. Bruce

For the National Institute of Standards and Technology



AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10018

TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Atlantic Testing Laboratories, Limited
Attn: Tom Hunter
P.O. Box 29

Canton, NY 13617

Date Received 01/09/09 AmeriSci Job # 209011610
Date Examined 01/13/09 P.O. # 4061
ELAP # 11480 Page 1 of 1
RE: CT5657; Timennan Hall, SUNY Potsdam; Potsdam, NY

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
A-1A 1	209011610-01 Location: Timennan Hall - Gray Ceiling Plaster	No	NAD (by NYS ELAP 198.1) by Albert Grohmann on 01/13/09
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
A-1B 1	209011610-02 Location: Timennan Hall - Gray Ceiling Plaster	No	NAD (by NYS ELAP 198.1) by Albert Grohmann on 01/13/09
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			

Reporting Notes:

Analyzed by: Albert Grohmann
*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 800/M4-82-020 per 40 CFR 763 (NVLAP Lab Code 200546-0), ELAP PLM Method 198.1 for NY friable samples or 198.6 for NOB samples (NY ELAP Lab ID11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile,FR 59,146,38970,8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab. This PLM report relates ONLY to the items tested. AIHA Lab # 102843.

Reviewed By: _____

END OF REPORT _____



ASBESTOS BULK SAMPLE CHAIN-OF-CUSTODY

No. 4061

Watertown:
26561 NYS Route 263
Watertown, NY 13801
315-786-7837 (T)
315-786-2022 (F)

Utica:
301 St. Anthony Street
Utica, NY 13501
315-795-3309 (T)
315-735-0742 (F)

Syracuse:
6085 Court Street Road
Syracuse, NY 13226
315-693-5281 (T)
315-699-3374 (F)

Rochester:
3-45 Winton Place
Rochester, NY 14623
585-627-9020 (T)
585-627-9021 (F)

Poughkeepsie:
251 Upper North Road
Highland, NY 12528
845-691-6998 (T)
845-691-6093 (F)

Plattsburgh:
1090 Military Turnpike
Plattsburgh, NY 12901
518-563-5876 (T)
518-562-1321 (F)

Elmira:
2330 Route 352
Elmira, NY 14903
607-737-9700 (T)
607-737-9714 (F)

Canton:
6431 U.S. Highway 11
Canton, NY 13517
315-398-4578 (T)
315-398-1012 (F)

Binghamton:
126 Park Avenue
Binghamton, NY 13903
607-773-1812 (T)
607-773-4835 (F)

Albany:
22 Corporate Drive
Clifton Park, NY 12065
518-933-9144 (T)
518-933-9166 (F)

Project No. CT5057	Project Name Timexman Hall	Date Collected 11/21/08	Laboratory Instructions <input type="checkbox"/> 12hr <input type="checkbox"/> 24hr <input type="checkbox"/> 48hr <input type="checkbox"/> 72hr <input checked="" type="checkbox"/> 5day <input checked="" type="checkbox"/> Positive Stop Analysis <input type="checkbox"/> If negative by PLM-NOB, analyze by TEM-NOB <input type="checkbox"/> Other:		Send Reports To (ATL Office): Canton Office	Report Distribution
Project Contact: Tory Russell	Project Location: SUNY Potsdam	Turn-Around Time: Page 1 of 1	Special Instructions:	ATL Contact: Tory Russell	Send Copy to: 315-386-1012	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Laboratory Sample ID No.
Field Sample No. A-1A	Sample Location Timexman Hall	Sample Description Grey	PLM	TEM-NOB	TEM-ONLY	MICRO-VAC
Field Sample No. A-1B	Sample Location Timexman Hall	Sample Description White Ceiling Plaster				
		Special Instructions Complete Ceiling Plaster				
		Received at Laboratory (Name): DR				
Sampler's Name: Tory Russell	Date: 11/21/08	Laboratory Signature: <i>[Signature]</i>	Date: 11/19	Shipment Rec'd Intact <input type="checkbox"/> Yes <input type="checkbox"/> No		
Sampler's Signature: <i>[Signature]</i>	Time: 11:00	Received at Laboratory (Name): DR	Date: 11/19	Field and Laboratory Remarks:		
Name: Tory Russell	Date: 12/10/08	Laboratory Signature: <i>[Signature]</i>	Time: 11:00			
Signature: <i>[Signature]</i>	Time: 6:00	Name: DR	Date: 11/19			
Name: Tory Russell	Date: 11/19	Signature: <i>[Signature]</i>	Time: 11:00			
Signature: <i>[Signature]</i>	Time: 11:00	Name: DR	Date: 11/19			

ATLANTIC TESTING LABORATORIES, Limited

OF-7c
Revised: 2/05

Distribution: White with Samples
Yellow to Laboratory
Pink to ATL Files

NEW YORK STATE - DEPARTMENT OF LABOR
DIVISION OF SAFETY AND HEALTH
LICENSE AND CERTIFICATE UNIT
STATE CAMPUS BUILDING 12
ALBANY, NY 12240

ASBESTOS HANDLING LICENSE

Atlantic Testing Laboratories, Limited
6431 US Highway 11
Canton, NY 13617

FILE NUMBER: 99-0911
LICENSE NUMBER: 29276
LICENSE CLASS: RESTRICTED
DATE OF ISSUE: 10/21/2008
EXPIRATION DATE: 11/30/2009

Duly Authorized Representative – Marijean B Remington

This license has been issued in accordance with applicable provisions of Article 30 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations (12 NYCRR Part 56). It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of an asbestos project, or (2) demonstrated lack of responsibility in the conduct of any job involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project worksite. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.



Maureen A. Cox, Director
FOR THE COMMISSIONER OF LABOR



EYES BLU
HAIR BLN
HGT 5' 08"

IF FOUND RETURN TO:
NYSOL - L&C UNIT
ROOM 161A BUILDING 12
STATE OFFICE CAMPUS
ALBANY NY 12240

STATE OF NEW YORK - DEPARTMENT OF LABO
ASBESTOS CERTIFICATE



TOREY J RUSSELL
CLASS(EXPIRES)
C-ATEC(07/09) D-INSP(07/09)
H-PM (07/09)

CERT# 06-09852
DMV# 834299222

MUST BE CARRIED ON ASBESTOS PROJECTS