



Response Labs, LLC.
12 Colvin Avenue, Albany NY 12206
Phone (518) 482-5630 Fax (518) 482-5624
NYS DOH ELAP # 11917

PLM Bulk Asbestos Report

Client: Ambient Environmental
12 Colvin Avenue
Albany NY 12206

Client Project Number: 110601AA

Project Name: SUNY Potsdam
Potsdam NY

Laboratory Job Number: 670-269

Sampling Area: Timmerman Building-135 Corridor and B5 Storage

Sampled By: Helen Thornley

Collection Date: 6/3/2011

Date Received: 6/6/2011

Lab Sample #	Customer Sample #	Homogeneous	Color	% Non-Fibrous Matrix Material	Gravimetric Test			Total % of Asbestos
					% of Organics	% of Acid Soluble Inorganics	% of Residue	
3618	003-01	Homogeneous	Grey	100%				NAD
Sampled Material: Ceiling Plaster					Non-Asbestos Fibers	%	Asbestos Types:	
Sample Location: Center Corridor 135					None Detected		No Asbestos Detected	
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1								
Microscope: Olympus BH-2-214 Turn Around Time: Same Day Rush					Analyzed Date: 6/6/2011			
3619	003-02	Homogeneous	Grey	100%				NAD
Sampled Material: Ceiling Plaster					Non-Asbestos Fibers	%	Asbestos Types:	
Sample Location: Center Corridor 135					None Detected		No Asbestos Detected	
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1								
Microscope: Olympus BH-2-214 Turn Around Time: Same Day Rush					Analyzed Date: 6/6/2011			
3620	003-03	Homogeneous	Grey	100%				NAD
Sampled Material: Ceiling Plaster					Non-Asbestos Fibers	%	Asbestos Types:	
Sample Location: Center Corridor 135					None Detected		No Asbestos Detected	
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1								
Microscope: Olympus BH-2-214 Turn Around Time: Same Day Rush					Analyzed Date: 6/6/2011			
3621	004-01	Homogeneous	Grey	100%				NAD
Sampled Material: Ceiling Plaster					Non-Asbestos Fibers	%	Asbestos Types:	
Sample Location: Center Storage B5					None Detected		No Asbestos Detected	
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1								
Microscope: Olympus BH-2-214 Turn Around Time: Same Day Rush					Analyzed Date: 6/6/2011			

Definitions of Abbreviations: **NOB:** Non-Organically Bound, **Trace:** Asbestos Detected at 1% or Less, **TEM:** Transmission Electron Microscope, **Inc.:** Inconclusive, **NAD:** No Asbestos Detected, **NA/PS:** Not Analyzed Positive Stop, **NA:** Not Analyzed

Disclaimer: PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. No Asbestos Detected or Trace results by PLM are considered inconclusive, TEM is currently the only method that can be used to determine if materials can be considered as non asbestos containing in NY State. This report cannot be reproduced except in full without the approval of Response Labs, LLC. This PLM report relates ONLY to the items tested. Liability is limited to the cost of analysis. ELAP PLM Method 198.1 for friable samples or 198.6 for NOB Samples.

Comments:

Laboratory Director,


Justin Adams



Response Labs, LLC.
 12 Colvin Avenue, Albany NY 12206
 Phone (518) 482-5630 Fax (518) 482-5624
 NYS DOH ELAP # 11917

PLM Bulk Asbestos Report

Project Name: SUNY Potsdam
 Potsdam NY

Laboratory Job Number: 670-269

Sampling Area: Timmerman Building-135 Corridor and B5 Storage

Sampled By: Helen Thörnley

Collection Date: 6/3/2011

Date Received: 6/6/2011

Lab Sample #	Customer Sample #	Homogeneous	Color	% Non-Fibrous Matrix Material	Gravimetric Test			Total % of Asbestos
					% of Organics	% of Acid Soluble Inorganics	% of Residue	
3622	004-02	Homogeneous	Grey	100%				NAD
Sampled Material: Ceiling Plaster					Non-Asbestos Fibers	%	Asbestos Types:	
Sample Location: Center Storage B5					None Detected		No Asbestos Detected	
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1								
Microscope: Olympus BH-2-214 Turn Around Time: Same Day Rush					Analyzed Date: 6/6/2011			
3623	004-03	Homogeneous	Grey	100%				NAD
Sampled Material: Ceiling Plaster					Non-Asbestos Fibers	%	Asbestos Types:	
Sample Location: Center Storage B5					None Detected		No Asbestos Detected	
Analyzed By: Adam C. Tucker Method: NYS ELAP 198.1								
Microscope: Olympus BH-2-214 Turn Around Time: Same Day Rush					Analyzed Date: 6/6/2011			

Definitions of Abbreviations: **NOB:** Non-Organically Bound, **Trace:** Asbestos Detected at 1% or Less, **TEM:** Transmission Electron Microscope, **Inc.:** Inconclusive, **NAD:** No Asbestos Detected, **NA/PS:** Not Analyzed Positive Stop, **NA:** Not Analyzed

Disclaimer: PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. No Asbestos Detected or Trace results by PLM are considered inconclusive, TEM is currently the only method that can be used to determine if materials can be considered as non asbestos containing in NY State. This report cannot be reproduced except in full without the approval of Response Labs, LLC. This PLM report relates ONLY to the items tested. Liability is limited to the cost of analysis. ELAP PLM Method 198.1 for friable samples or 198.6 for NOB Samples.

Comments:

Laboratory Director,

Justin Adams