



AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Atlantic Testing Laboratories,
Limited
Attn: Tom Hunter
P.O. Box 29
Canton, NY 13617

Date Received 09/22/07

AmeriSci Job No. 207093565

Date Examined 09/22/07

P.O. # 0577

ELAP Number 11480

Page 1 of 2

RE CT5428; Timmerman Hall; SUNY Potsdam, NY

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1A	207093565-01 Location: Bathroom B-100, Grey Mudded Fitting	No	NAD (by NYS ELAP 198.1) by Charmel A. Dozier on 09/22/07
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 30 %, Non-fibrous 70 %			
1B	207093565-02 Location: Bathroom B-100, Grey Mudded Fitting	No	NAD (by NYS ELAP 198.1) by Charmel A. Dozier on 09/22/07
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 30 %, Non-fibrous 70 %			
3B	207093565-03 Location: Bathroom B-100, White Gypsum Board	No	NAD (by NYS ELAP 198.1) by Charmel A. Dozier on 09/22/07
Analyst Description: White/Grey, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Non-fibrous 100 %			
3A	207093565-04 Location: Bathroom B-100, White Gypsum Board	No	NAD (by NYS ELAP 198.1) by Charmel A. Dozier on 09/22/07
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Non-fibrous 100 %			
2A	207093565-05 Location: Mechanical Room / HWS, Grey Elbow	No	NAD (by NYS ELAP 198.1) by Charmel A. Dozier on 09/22/07
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 30 %, Non-fibrous 70 %			

See Reporting notes on last page

Client Name: Atlantic Testing Laboratories, Limited

PLM Bulk Asbestos Report

CT5428; Timmerman Hall; SUNY Potsdam, NY

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
Reporting Notes:	<i>Charmel A. Dozier</i>		

Analyzed by: Charmel A. Dozier

*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab Code 200546-0), ELAP PLM Method 198.1 for NY friable samples or 198.6 for NOB samples (NY ELAP Lab ID11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile,FR 59,146,38970,8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab. This PLM report relates ONLY to the items tested. AIHA Lab # 102843.

Reviewed By: _____

END OF REPORT _____



ASBESTOS BULK SAMPLE CHAIN-OF-CUSTODY

No. 0577

Albany

22 Corporate Drive
Chilton Park, NY 12065
518/863-9164 (T)
518/863-9166 (F)

Binghamton

126 Park Avenue
Binghamton, NY 13903
607/733-1812 (T)
607/733-1835 (F)

Canton

6431 U.S. Highway 11
Canton, NY 13617
607/336-4578 (T)
315/336-1012 (F)

Elmira

2330 Route 352
Elmira, NY 14808
607/737-0750 (T)
607/737-0714 (F)

Pittsburgh

1400 Military Turnpike
Pittsburgh, NY 12901
518/563-5672 (T)
518/562-1321 (F)

Poughkeepsie

251 Upper North Road
Highland, NY 12528
845/691-6098 (T)
845/691-6093 (F)

Rochester

3445 Wilson Place
Rochester, NY 14623
583/427-8020 (T)
583/427-9021 (F)

Syracuse

5895 State Route 31
Cortro, NY 13039
315/699-5287 (T)
315/699-3874 (F)

Utica

301 S. Anthony Street
Utica, NY 13501
315/735-8302 (T)
315/735-0742 (F)

Watertown

26551 RYS Route 263
Watertown, NY 13621
315/705-7897 (T)
315/705-2022 (F)

Project No. CT5428		Project Name Timmanan Hall		Date Collected 9/20/07		Page 1 of 1		Special Instructions:		<input type="checkbox"/> 12hr <input checked="" type="checkbox"/> 24hr <input type="checkbox"/> 48hr <input type="checkbox"/> 72hr		Serial Reports (30) (ATTN: Office)		Report Distribution: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Project Contact: Joe Emabrowski		Project Location: @ Potsdam N.Y.		Sample Location: PLM		Sample Description: Muddled Fitting		<input type="checkbox"/> Positive Stop Analysis <input type="checkbox"/> If negative by PLM-NOB, analyze by TEM-NOB		Send Copy To: Joe Emabrowski Fax Results: <input checked="" type="checkbox"/> Yes		Fax Results: <input type="checkbox"/> No		Laboratory Sample ID No. 207093505	
Sampler's Name: Torey Russell		Sampler's Signature: <i>[Signature]</i>		Date: 9/20/07		Time: 11:00		Received at Laboratory (Name):		Laboratory Signature: <i>[Signature]</i>		Date: 9/20/07		Time: 11:20	
Name: Torey Russell		Signature: <i>[Signature]</i>		Date: 9/20/07		Time: 11:30		Name: [Signature]		Signature: <i>[Signature]</i>		Date: 9/20/07		Time: 11:20	
Name: Torey Russell		Signature: <i>[Signature]</i>		Date: 9/20/07		Time: 11:30		Name: [Signature]		Signature: <i>[Signature]</i>		Date: 9/20/07		Time: 11:20	

Distribution: Write with Samples Yellow to Laboratory Pink to ATL Files

ATLANTIC TESTING LABORATORIES, Limited