



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-9392

December 18, 2010

Ambient Environmental, Inc.
Attn: Joella Viscusi
12 Colvin Avenue
Albany, NY 12206

RE: Ambient Environmental, Inc.
Job Number 210123189
P.O. #101214AB
101214AB; SUNY Potsdam; Timmerman Hall - Bulk Sampling

Dear Joella Viscusi:

Enclosed are the results of Asbestos Analysis - Bulk Protocol of the following Ambient Environmental, Inc. samples, received at AmeriSci on Saturday, December 18, 2010, for a rush turnaround:

01-01, 01-02, 02-01, 02-02

The 4 samples, placed in Zip Lock Bag, were shipped to AmeriSci via Federal Express. Ambient Environmental, Inc. requested ELAP PLM/TEM analysis of these samples.

The results of the analyses which were performed following ELAP Protocols 198.1 PLM Friable and/or 198.6 for PLM NOB. ELAP Protocol 198.4 TEM NOB guidelines are presented within the Summary Table of this report. The presence of matrix reduction data in the Summary Table normally indicates an NOB sample. For NOB samples the individual matrix reduction, combined PLM and TEM analysis results are listed in the Summary Bulk Asbestos Analysis Results in Table I. Complete PLM results for individual samples are presented in the PLM Bulk Asbestos Report. This combined report relates ONLY to sample analysis expressed as percent composition by weight and percent asbestos. This report must not be used to claim product endorsement or approval by these laboratories, NVLAP, ELAP or any other associated agency. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the written approval of the laboratory. This report may contain specific data not covered by NVLAP or ELAP accreditations respectively, if so identified in relevant footnotes.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Paul J. Mucha".

Paul J. Mucha
Laboratory Director



AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Ambient Environmental, Inc.
Attn: Joella Viscusi
12 Colvin Avenue

Albany, NY 12206

Date Received 12/18/10 **AmeriSci Job #** 210123189
Date Examined 12/18/10 **P.O. #**
ELAP # 11480 **Page** 1 of 2
RE: 101214AB; SUNY Potsdam; Timmerman Hall - Bulk Sampling

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
01-01 1	210123189-01 Location: 9"x9" Brown Floor Tile, Basement - B004 Door	Yes	3.2 % (ELAP 198.6; 400pc) by Ravi N. Krishnappa on 12/18/10
Analyst Description: Black/Brown, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 3.2 % Other Material: Non-fibrous 46.2 %			
01-02 1	210123189-02 Location: 9"x9" Brown Floor Tile, First Floor - Stairwell Landing		NA/PS
Analyst Description: Bulk Material Asbestos Types: Other Material:			
02-01 2	210123189-03 Location: Black Mastic For Floor Tile, Basement - B004 Door	Yes	1.8 % (by NYS ELAP 198.6) by Ravi N. Krishnappa on 12/18/10
Analyst Description: Black, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 1.8 % Other Material: Non-fibrous 6.2 %			
02-02 2	210123189-04 Location: Black Mastic For Floor Tile, First Floor - Stairwell Landing		NA/PS
Analyst Description: Bulk Material Asbestos Types: Other Material:			

Client Name: Ambient Environmental, Inc.

PLM Bulk Asbestos Report

101214AB; SUNY Potsdam; Timmerman Hall - Bulk Sampling

Reporting Notes:

Analyzed by: Ravi N. Krishnappa 

*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab Code 200546-0), ELAP PLM Method 198.1 for NY friable samples or 198.6 for NOB samples (NY ELAP Lab ID11480);

Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile,FR 59,146,38970,8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab. This PLM report relates ONLY to the items tested. AIHA Lab # 102843.

Reviewed By:  _____

_____END OF REPORT_____

A AMBIENT ENVIRONMENTAL, INC.
 12 Colvin Avenue
 Albany, NY 12206
 PH: 518-482-0704
 Fax: 518-482-0750

**BULK SAMPLE DATA AND
 CHAIN OF CUSTODY FORM**

210128189

PROJECT INFORMATION

1. Client: SUNY POTSDAM	2. Project Name: TIMMERMAN HALL - SAMPLING	2a. Project Address:	2b. Client Contact: LARRY Leashomb
3. Project Number: 101214AB	3a. Task Number:	4. Inspector: R. Giordano	5. Collection Date: 12-17-10
6. Sample TAT: <input type="checkbox"/> 24 HR <input type="checkbox"/> 48 HR <input type="checkbox"/> 72 HR <input type="checkbox"/> 5 Day <input checked="" type="checkbox"/> Other POTSDAM	7. Building Name: TIMMERMAN HALL	9. Comments: (Field) <input checked="" type="checkbox"/> Analyze to First Positive By Homogeneous Material <input checked="" type="checkbox"/> For Negative NOB PLM's, continue to TEM	

BULK SAMPLE LOCATION

10. Homogeneous Area Number	11. Bulk Sample ID Number	12. Sampled Material	13. Type of Material			14. Sample Location	15. Friability (N/F)	16. Condition (G, D, SD)	17. Quantity (LF, SF, EA)	18. Asbestos Content (Type & %)
			Surf	TSI	MISC					
01	01	9"x9" Brown Floor Tile			✓	Basement - Booth Door	N			
01	02	9"x9" Brown Floor Tile			✓	First Floor - Stairwell Landing	N			
02	01	Black Mastic for Floor Tile			✓	Basement - Booth Door	N			
02	02	Black Mastic for Floor Tile			✓	First Floor - Stairwell Landing	N			

CHAIN OF CUSTODY

19. Relinquished By: R. Giordano	20. Date 12-17-10	21. Time 14:30	22. Received By: KOLBA W	23. Date 12-16-10	24. Time 12:49
II					
III					

LAB INFORMATION

25. Lab Name	26. Date	27. Time
a. Analyzed By:		
b. QC by:		
c. Lab Batch #:		

28. Ambient Project Manager:
SOELIA VISCUSI

29. Results To: **Rob Giordano**
 Phone #s:
 Fax:

30. Drawings: Sample Locations
 Material Locations

31. Comments: **email: robgiordano@nycaf.rr.com**